

GOVERNMENT OF ANDHRA PRADESH
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT

From :
The Director General,
State Disaster Response and Fire Services,
Andhra Pradesh, Vijayawada.

To :
The Management,
M/s LRG Public School, represented
by Jagatheesan, Sy.No.105-1B,
119-2, Kirikera, Hindupur,
Sri Satya Sai District.

Rc.No.3840/A3/2017/SSS (MSB-SR), Dated:02-06-2022.

Sir,

Sub: A.P. State Disaster Response and Fire Services Department-
MSB Section-Issuance of Renewal of No Objection Certificate to the
Existing Building of M/s LRG Public School, represented by
Jagatheesan, Sy.No.105-1B, 119-2, Kirikera, Hindupur, Sri satya Sai
District-Regarding.


Ref: 1. Occupancy NOC Rc.No.3840/A3/2017, Dt:07.10.2017 of District
Fire Officer, Anantapuram District.
2. Application of M/s LRG Public School, represented by
Jagatheesan, Sy.No.105-1B, 119-2, Kirikera, Hindupur, Sri satya
Sai District.

The Management of M/s LRG Public School, represented by Jagatheesan,
Sy.No.105-1B, 119-2, Kirikera, Hindupur, Sri satya Sai District has requested to issue
Renewal of No Objection Certificate by duly remitting the Renewal Fee towards Fire
Precautionary Fee vide reference 2nd cited.

2) The No Objection Certificate for Occupancy was issued vide reference 1st cited to
the Existing Building of M/s LRG Public School, represented by Jagatheesan, Sy.No.105-1B,
119-2, Kirikera, Hindupur, Sri satya Sai District with Block-1 have Ground Floor with Built-
up area of 267.06 Sq.Mtrs., with a Height of 04.87 Mtrs., & Block-2 have Ground Floor with
Built-up area of 728.16 Sq.Mtrs., with a Height of 04.87 Mtrs., for Educational Occupancy.

3) The Management has submitted the Self-Certification report and stated that the
furnished information is correct and it is noticed at any time that the information provided is
false, they understand that Renewal NOC deemed may be cancelled by the concerned
authority.

4) In view of the above and taking into consideration of the larger public interest and
in the context of the COVID-19 pandemic across the country and also based on the Self-
Certification submitted by the Management, the Renewal of No Objection Certificate is issued
to the Existing Building of M/s LRG Public School, represented by Jagatheesan, Sy.No.105-
1B, 119-2, Kirikera, Hindupur, Sri satya Sai District with Block-1 have Ground Floor with
Built-up area of 267.06 Sq.Mtrs., with a Height of 04.87 Mtrs., & Block-2 have Ground Floor
with Built-up area of 728.16 Sq.Mtrs., with a Height of 04.87 Mtrs., for Educational
Occupancy.



Principal
L.R.G. Public School


Secretary & Correspondent
L.R.G. Public School
KIRIKERA - 515 211

(contd....2p)

5) It is suggested to the Management for providing the following Fire Safety Measures keeping in view of Practicality, Maintenance and Resilience.

Sl. No.	Fire Fighting Equipment	Prescribed	Available with Nos.	Deficit
1	Fire Extinguishers	ABC/CO2 type (04 + 20)	24 Nos.	Nil
2	Underground parking/ Cellar / Basement	Temperature Sensors connected to "Hooter" and that can give alerts through Cell phone instead of Sprinklers.	NA	Nil
3	Manual Call Point System	One Number per Floor (01 + 01)	02 Nos.	Nil
4	Under Ground Static Water Tank (or) Terrace Water Tank.	5,000 Ltrs. (Minimum)	10,000 Ltrs.	Nil
5	2 HP (Pump + Electrical Motors connected)* @ one per Floor connected to Normal Plumbing System instead of Down Comer/Special Pipes.	One per each Floor (01 + 01) (Total 02 Floors)	02 Nos.	Nil
6	5 HP (Mobile Pump + Petrol Engine on wheels connected to Ground Floor Sump).	NA	Nil	Nil

6) Electrical Safety System:

(i) Miniature Circuit Breakers, MCB's.	: Yes, Provided
(ii) No Overloading of Power Sockets.	: Yes, Ensured
(iii) Whether, 10 years old wiring to be changed specially wherever A/c is there ?	: Yes, Ensured
(iv) LED Lights in Closed Rooms, Corridors, Staircases connected to Inverter (Battery).	: Yes, Connected
(v) Grounding/Earthing is provided.	: Yes, Provided
(vi) Lightening Conductor is provided.	: Not Applicable
(vii) The above shall be certified by authorized Electrical Contractor/Supervisor.	: Not Applicable

7) Fire Safety Suggestions:

Sl. No.	As Builder	As Occupant	As Security personnel
1.	All the Fire protection arrangements shall be maintained in good working condition at all time.	The Escape/Exit roots shall not be kept Locked/Blocked or Encroached.	All the occupants must be trained the correct method of operation of the Fire Fighting System installed.
2.	Any loss of life or property due to non-functioning of Fire Safety Measures and other Installations shall be the responsibility of the management.	All occupants shall be trained to operate the Fire Safety Equipment during Emergency.	Mock Drills should be conducted once in 03 months for initial two years. Thereafter, once in every 06 months.
3.	Addition/Alteration, if any in the Building may be verified by Building Authority.	Mock Drills should be conducted once in 03 months for initial two years. Thereafter, once in every 06 months.	All Security Personnel shall be trained to operate the Fire Safety Equipment during Emergency.
4.	This Renewal of No Objection Certificate should be from Fire Safety Officer.	Raise the alarm If the Fire cannot be controlled, Evacuate the area completely at once with nearest Safe Exit.	Attack the Fire using available Fire Equipment only if you feel capable of controlling it. If not, take all steps to isolate the area by closing Doors and Windows.


Bhavesh
Principal

Secretary & Correspondent
L.R.G. Public School
KIRIKERA - 515211

Prakash

8) This Renewal of No Objection Certificate is valid for a period of Five (05) years from the date of issue of this letter to the Management of M/s LRG Public School, represented by Jagatheesan, Sy.No.105-1B, 119-2, Kirikera, Hindupur, Sri satya Sai District subject to the compliance of above Fire and Electrical Safety Measures. The Owner/Occupier/Builder/Management concerned of the Building shall submit Affidavit/Self Declaration/Certification with regard to working condition of above Fire Safety System every year in the prescribed format and submit/upload the photographs of the Mock Drills conducted in the premises. It is the responsibility of the Builder to maintain the Fire Safety Equipment in good working condition at all times and apply for next Periodical Renewal of No Objection Certificate, duly remitting the User Charges vide G.O.Ms.No.90, Home (Prisons & Fire Services) Department, Dated:13.08.2021 & G.O.Ms.No.120, Home (Prisons & Fire Services) Department, Dated:25.10.2021, two (02) months before expiry of this Renewal of No Objection Certificate.

Yours Sincerely,




Director General,


State Disaster Response and Fire Services,
Andhra Pradesh, Vijayawada.

Copy to the Management, M/s LRG Public School, represented by Jagatheesan, Sy.No.105-1B, 119-2, Kirikera, Hindupur, Sri satya Sai District.
Copy to the District Educational Officer, Sri Satya Sai District.

Note: In case of any emergency call to 101 or State Fire Control Room-9100108101.



Principal
LRG Public School



Secretary & Correspondent
L.R.G.Public School
KIRIKERA - 515 211